Marrangaroo Environmental Protection Licence (EPL) 1464

Water Monitoring Data

L2.4 Water Concentration Limits		
Pollutant	**Units of Measure**	**Concentration limit**
Oil & Grease	Milligrams per litre	10
pH	pH	6.5-8.5
Total suspended solids	Milligrams per litre	30

2016	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Oil & Grease	Nil Release	Nil Release	Nil Release	Nil Release	Nil Release	Nil Release	Nil Release	Nil Release	Nil Release	Nil Release	Nil Release	Nil Release
pH	Nil Release	Nil Release	Nil Release	Nil Release	Nil Release	Nil Release	Nil Release	Nil Release	Nil Release	Nil Release	Nil Release	Nil Release
Total suspended solids	Nil Release	Nil Release	Nil Release	Nil Release	Nil Release	Nil Release	Nil Release	Nil Release	Nil Release	Nil Release	Nil Release	Nil Release